



We help ideas meet the real world



# Compliance Statement

No. 2011-126

## Connecting Hardware, Category 6A

### Company

KRUGEL EXIM spol. S r.o.  
Rybnicna 38/H  
831 06 Bratislava  
Slovak Republic

### Product description

Screened Category 6A RJ45 Jack and Patch Panel characterised up to 500 MHz, 100  $\Omega$

### Product identification

KELine RJ45 Jack. Part number: KEJ-C6A-S-10G  
KELine Patch Panel. Part number: KEP-C6A-S-10G

### Generic cabling and cabling components standards – Category 6A connector requirements

- ISO/IEC 11801:2002 (Ed. 2.0), including amendments A1:2008 and A2:2010
- IEC 60603-7-51:2010
- EN 50173-1:2007, including amendments A1:2009 and FprAB:2010
- ANSI/TIA-568-C.2:2009

including all connector alien crosstalk parameters (PS ANEXT and PS AFEXT)

### Technical report

DELTA-N312816-03, DANAK-19J2319

### Certificate valid until

19 May 2012

This product has been tested by EC Cabling Group of DELTA and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The testing included measurement of NEXT with a compliant test plug and calculation of all the 14 test cases in both measurement directions. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis once a year.

Hørsholm, 19 May 2011

Erik Bech  
Test Manager

Claude Videt  
Project Manager

### DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
[www.madebydelta.com/cable](http://www.madebydelta.com/cable)



TEST Reg. no. 19